



No. 2620/0019-G-CER

Certificate of Conformity

48/15000/200-100/100

15 kVA / 12 kW

230 Vac

50 Hz

200 A / 350 A

By the product certificate number

Issued to

License holder: Victron Energy B. V.

De Paal 35, 1351 JG Almere - Netherlands

Trademark:

victron energy

Contract number: 801264

It is certified that the product:

Type of generator: Inverter / charger with UPS functionality.

> AC (grid): 2 inputs and 2 outputs. DC (batteries): 1 input and 1 output.

Family: Quattro

Models: **Technical Data:** Rated AC Power Rated AC Voltage

> Rated AC Frequency DC Current (IN / OUT) DC Voltage (IN / OUT) Firmware version Number of phases

48 Vdc 2656475.1 Single Phase Isolation transformer Yes

48/10000/140-100/100 10 kVA / 8 kW 230 Vac 50 Hz

140 A / 235 A 48 Vdc 2653475.1 Single Phase Yes

48/8000/110-100/100 8 kVA / 6.5 kW 230 Vac

50 Hz 100 A / 188 A 48 Vdc 2655475.1 Single Phase Yes

Is in compliance with the regulation:

EN 50549-1: 2019; Requirements for generating plants to be connected in parallel with distribution networks - Part 1: Connection to a LV Distribution Network - Generating Plants up to and including type B.

In exception to:

Static accuracy for Voltage related control modes stated in the clause 4.7.2.3.3 of the above-mentioned standard The static accuracy of the certified inverter / charger is not compliant with the clause 4.7.2.2 of the standard. According to this clause, the reactive power capability shall be provided with an accuracy of ± 2 % Smax. Per test results, the maximum deviation obtained for the static accuracy is within ± 3.1 % Smax.

Additional remark: The certified inverter / charger has just a single integrated switch. Double switching requirements stated in the clause 4.3.2 of the certified standard need to be accomplished at the connection point by means of the installation of an additional external device, as per manufacturer specification. For these products, the manufacturer recommends installing the Voltage and Frequency Relay manufactured by Ziehl, model UFR1001E.

The above-mentioned product is certified according to the standard EN 50549-1: 2019 and is valid to be installed in PV generating of type plants up to and including type A to be connected to a LV distribution network. The relation between this European Standard with the relevant Article of COMMISSION REGULATION (EU) 2016/631 (NC RfG) is considered as it is indicated in the annex H of the standard EN 50549-1:2019.

The above-mentioned generating unit is certified according to the SGS internal procedure PE.T-ECPE-53 based on the requirements of the UNE-EN ISO / IEC 17065.

This certificate is first issued on: 13th May 2021. This certificate is valid until: 13th May 2024.

Madrid, 13th May 2021

Daniel Arranz Muñiz Certification Manager



SGS Tecnos, S.A. C/ Trespaderne, 29 - 28042 Madrid This certificate is issued by SGS under its General Conditions for Product Certification at The manufacturer information, in addition to the status and validity of the certificate can be checked scanning the QR code above included or through the following web link database:

This document cannot be reproduced partially

No. 2620/0019-G-CER Page 1 of 1